

EXHIBIT 21

Adopt the *International Energy Conservation Code 2006* with the following amendments:

1. Amend Section 101.1 as follows:

101.1 Title. These regulations shall be known as the *International Energy Conservation Code* of [NAME OF JURISDICTION] the State of New Hampshire hereinafter referred to as "this code."

2. Amend Section 101.2 as follows:

101.2 Scope. This Code applies to residential and commercial buildings.

Exception: Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than three stories above grade plane in height with a separate means of egress and their accessory structures shall comply with PUC 1800 Rules.

3. Amend Section 101.5 as follows:

101.5 Compliance: Residential Buildings shall meet the provisions of Chapter 4. Commercial buildings shall meet the provisions of Chapter 5.

Exception: Any structure three stories or less above grade plane in height and less than 4,000 ft² (372 m²) in gross floor area are permitted to show compliance based on Chapter 4.

101.5.1 Compliance materials. (no change)

101.5.2 Low energy buildings. The following buildings, or portions thereof, separated from the remainder of the building by building thermal envelope assemblies complying with the code shall be exempt from the building thermal envelope provisions of this code:

1. Those with a peak design rate of energy usage less than 3.4 Btu/h.ft² (10.7 W/m²) or 1.0 watt/ft² (10.7 W/m²) of floor area for space conditioning purposes.
2. Those that do not contain conditioned space.
3. Greenhouses that are provided with a separate temperature control system.

4. Amend Section 403.4 as follows:

403.4 Circulating hot water systems. All circulating service hot water piping shall be insulated to at least R-2. Circulating hot water systems shall include an automatic or readily accessible manual switch that can turn off the hot water circulating pump when the system is not in use.

403.4.1. Circulating domestic hot water pipes shall be insulated to a minimum of R-4 and non-circulating domestic hot water pipes in unconditioned spaces shall be insulated to a minimum of R-4.

EXHIBIT 21

5. Amend Section 504.5 as follows:

504.5 Pipe insulation. (no change).

504.5.1. Circulating domestic hot water pipes shall be insulated to a minimum of R-4 and non-circulating domestic hot water pipes in unconditioned spaces shall be insulated to a minimum of R-4.