

## **EXHIBIT 64**

### **2009 International Plumbing Code**

#### **New Amendment Proposal IPC 2009 – Adopt Appendix G**

**CURRENT LANGUAGE:**

This appendix was not previously adopted.

**PROPOSED CHANGE:**

**Adopt Appendix G – Vacuum Drainage System**

**REASON:**

Reason for Adopting Appendix G: These systems are used often in NH thus both installers and inspectors need to have this system defined as a code accepted alternative. Vacuum drainage systems are used in supermarkets so that they do not have to relocate floor drains every time they move a food case. Adopting this appendix allows the system to be used whenever appropriate.