

EXHIBIT 80

NEW HAMPSHIRE STATE BUILDING CODE PROPOSED AMENDMENT TO THE IECC 2009

Applicable Code language (including section numbers):

403.4 Circulating hot water systems. All circulating service hot water piping shall be insulated to at least R-2. Circulating hot water systems shall include an automatic or readily accessible manual switch that can turn off the hot water circulating pump when the system is not in use.

Current Code language:

403.4 Circulating hot water systems. All circulating service hot water piping shall be insulated to at least R-2. Circulating hot water systems shall include an automatic or readily accessible manual switch that can turn off the hot water circulating pump when the system is not in use.

Proposed Code language:

403.4 Circulating hot water systems. All circulating service hot water piping shall be insulated to at least R- 4. Circulating hot water systems shall include an automatic or readily accessible manual switch that can turn off the hot water circulating pump when the system is not in use.

Reason/Justification: This amendment will continue to use the higher level of pipe insulation in residential construction that New Hampshire has required in the IECC 2006.