

EXHIBIT 96

Automatic door current amendment:

1105.1 Public entrances. In addition to *accessible* entrances required by Sections 1105.1.1 through 1105.1.6, at least 60 percent of all *public entrances* shall be *accessible*. At least one of the required accessible public entrances in Groups A, E, I-1, I-2, I-3, M, R-1 and R-2; and all buildings greater than 1,000 square feet (93 m²) in Group B, and the nonresidential portion of live/work units per Section 419 greater than 1,000 square feet (93 m²) shall be equipped with full powered automatic doors in compliance with ICC A117.1. Where an automatic door is not provided, a mechanism to alert the owner of a presence at the door shall be provided.

Exceptions:

1. An *accessible* entrance is not required to areas not required to be *accessible*.
2. Loading and *service entrances* that are not the only entrance to a tenant space.

Proposed revised amendment:

(12) Amend section **1005.1** of the *International Building Code 2009* by replacing said section with the following [effective May 14, 2010]:

1105.1 Public entrances. In addition to *accessible* entrances required by Sections 1105.1.1 through 1105.1.6, at least 60 percent of all *public entrances* shall be *accessible*.

1105.1.1 At least one of the required *accessible public entrances* in Groups A, E, I-1, I-2, I-3, R-1 and R-2 shall be equipped with automatic doors in compliance with ICC A117.1.

1105.1.2 At least one of the required *accessible public entrances* in Groups B and M greater than or equal to 1,000 net square feet (93 m²) in size and the nonresidential portion of live/work units per Section 419 greater than or equal to 1,000 net square feet (93 m²) shall be equipped with automatic doors in compliance with ICC A117.1.

1105.1.2.1 Required accessible public entrances in Groups B and M less than than 1,000 net square feet (93 m²) in size and the nonresidential portion of live/work units per Section 419 less than 1,000 net square feet (93 m²) where automatic doors are not provided, an electric signaling device to alert the owner of a presence at the door shall be provided.

Exceptions:

1. An *accessible* entrance is not required to areas not required to be *accessible*.
2. Loading and *service entrances* that are not the only entrance to a tenant space.

Reasons for the revised amendment:

1. Typo of the proposed language, stating to “amend section 1005.1.”
2. Clarifying that the square footage of the area of the building in the use group shall be a “net” measured area, not the gross area of the entire building which may include storage space, other Use group areas, etc.
3. Clarifying that the requirement for an electric signaling device (ie., doorbell or intercom) is required for the less than 1000 net sq ft use group building areas; it is not the intent to require doorbells at all entrances where power operated doors are not required.