

**NEW HAMPSHIRE STATE BUILDING CODE  
PROPOSED AMENDMENT FORM**

**Proposed amendment submitted by:**

**PL-15-11-15**

Name: 2015 IPC Review Committee

Date: June 11, 2015

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: 602-223-3889 E-mail: bldcodebrd@dos.nh.gov

**Applicable code:** 2015 IPC (Adoption pending)

**Applicable code section:**

Select only one code: IEBC-15 IBC-15 IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-14 (NFPA 70)

**Current language** (including section numbers and include prior adopted amendments):

**705.11.2 Solvent Cementing.** Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564, CSA B137.3, CSA B181.2 or CSA B182.1 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM D 2855. Solvent-cement joints shall be permitted above or below ground.

**Exception:** A primer is not required where both of the following conditions apply:

1. The solvent cement used is third-party certified as conforming to ASTM D 2564.
2. The solvent cement is used only for joining PVC drain, waste and vent pipe and fittings in non-pressure applications in sizes up to and including 4 inches in diameter.

**Check one:**  Delete without substitution:  Add new section to read as follows:

Delete section and substitute the following:   X  Revise section to read as follows:

~~Show Line through material to be deleted.~~ Underline material to be added.

**Proposed code language:**

**705.11.2 Solvent Cementing.** Joint surfaces shall be clean and free from moisture. A ~~purple~~ primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564, CSA B137.3, CSA B181.2 or CSA B182.1 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM D 2855. Solvent-cement joints shall be permitted above or below ground.

**Exception:** A primer is not required where both of the following conditions apply:

1. The solvent cement used is third-party certified as conforming to ASTM D 2564.
2. The solvent cement is used only for joining PVC drain, waste and vent pipe and fittings in non-pressure applications in sizes up to and including 4 inches in diameter.

**Reason / Justification:**

This has been a long standing amendment that was generated by the plumbing community due to the purple primer being a problem.

**Financial Analysis/Fiscal Impact of proposed amendment: NONE**

---

**For Building Code Review Board Use:**

Not approved: \_\_\_\_\_ Approved:  \_\_\_\_\_ Approved with modifications: \_\_\_\_\_

Scheduled Hearing Date: August 14, 2015 Exhibit #: PL-15-11-15

Chair's Signature:  Date: September 11, 2015

Printed Name: Shawn Bergeron, Sr.