

NEW HAMPSHIRE STATE BUILDING CODE  
PROPOSED AMENDMENT FORM

RE-15-05-15

Proposed amendment submitted by:

Name: IRC Review Subcommittee

Date: 24 Nov 14

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: E-mail: 603-223-3888/ Bldgcodebrd@dos.nh.gov

Applicable code: 2015 IRC Applicable code section: Table R301.2(1)

Select only one code: IEBC-15 IBC-15 IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-14 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

**Table R301.2(1) Climatic and Geographic Design Criteria.** (The table does not have a footnote providing a source for ground snow load data.)

Check one: \_\_\_ Delete without substitution:  Add new section to read as follows:

\_\_\_ Delete section and substitute the following: \_\_\_ Revise section to read as follows:

Show Line through material to be deleted. Underline material to be added.

Proposed code language:

(4) Add reference to footnote "n" to the Ground Snow Load column of TABLE R301.2(1) Climatic and Geographic Design Criteria and add footnote "n" below.

"n. The jurisdiction may fill in this part of the table with the ground snow load from Figure R301.2(5) or from Table 1 of Ground Snow Loads for New Hampshire ERDC/CRREL TR-2-6."


Reason / Justification: Provides approved sources of Ground Snow Load Data for use by the local jurisdiction. (Carry over from amendments to the 2009 IRC)

Financial Analysis/Fiscal Impact of proposed amendment: None

For Building Code Review Board Use:

Not approved: \_\_\_\_\_ Approved: XX Approved with modifications: \_\_\_\_\_

Scheduled Hearing Date: July 10, 2015 Exhibit #: RE-15-05-15

Chair's Signature:  Date: July 10, 2015

Printed Name: Shawn Bergeron, Sr.