

NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM

RE-15-07-15

Proposed amendment submitted by:

Name: IRC Review Subcommittee

Date: 24 Nov 14

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: E-mail: 603-223-3888/ Bldgcodebrd@dos.nh.gov

Applicable code: 2015 IRC Applicable code section: R313.2

Select only one code: IEBC-15 IBC-15 IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-14 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

R313.2 One- and two-family dwelling automatic fire systems. An automatic residential fire sprinkler system shall be installed in one- and two-family *dwellings*.

Exception: An automatic residential fire sprinkler system shall not be required for *additions* or *alterations* to existing buildings that are not already provided with an automatic residential sprinkler system.

R313.2.1 Design and installation. Automatic residential fire sprinkler systems shall be designed and installed in accordance with section P2904 or NFPA 13D.

Check one: ___ Delete without substitution: Add new section to read as follows:

___ Delete section and substitute the following: ___ Revise section to read as follows:

Show Line through material to be deleted. Underline material to be added.

Proposed code language:

R313.2 One- and two-family dwelling automatic fire systems. ~~An automatic residential fire sprinkler systems shall not be installed~~ required in one- and two-family *dwellings*.

~~**Exception:** An automatic residential fire sprinkler system shall not be required for *additions* or *alterations* to existing buildings that are not already provided with an automatic residential sprinkler system.~~

R313.2.1 Design and installation. Automatic residential fire sprinkler systems shall be designed and installed in accordance with section P2904 or NFPA 13D.

R313.2.2 One- and two-family dwellings automatic fire systems. Buildings provided with an automatic residential fire sprinkler system shall be allowed to exercise all credits regarding egress in accordance with RSA 155-A:2 II (NFPA 101).


Reason / Justification: Comply with RSA 155A:10. (Carry over from amendments to 2009 IRC.)

Financial Analysis/Fiscal Impact of proposed amendment: None.

For Building Code Review Board Use:

Not approved: _____ Approved: XX Approved with modifications: _____

Scheduled Hearing Date: July 10, 2015 Exhibit #: RE-15-07-15

Chair's Signature:  Date: July 10, 2015

Printed Name: Shawn Bergeron, Sr.