

NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM

Proposed amendment submitted by:

RE-15-08-15

Name: IRC Review Subcommittee

Date: 24 Nov 14

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: E-mail: 603-223-3888/ Bldgcodebrd@dos.nh.gov

Applicable code: 2015 IRC Applicable code section: **N1102.1**

Select only one code: IEBC-15 IBC-15 **IRC-15** IPC-15 IMC-15/ECC-15 IEBC-15 NEC-14 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

N1102.1 (R402.1) General (Prescriptive). The Building thermal envelope shall meet the requirements of Sections N1102.1.1 through N1102.1.4.

Check one: ___ Delete without substitution: ___ Add new section to read as follows:

___ Delete section and substitute the following: **X** Revise section to read as follows:

Show Line through material to be deleted. Underline material to be added.

Proposed code language:

N1102.1 (R402.1) General (Prescriptive). The Building thermal envelope shall meet the requirements of Sections N1102.1.1 through N1102.1.4. or the requirements of section 305 of the ICC-400 2012 Standard on the Design and Construction of Log Structures.

Reason / Justification: (Carry over from amendments to 2009 IRC.) Allows trade off's in envelope criteria to allow Log Homes to meet the requirements of the code.

Financial Analysis/Fiscal Impact of proposed amendment: None.


For Building Code Review Board Use:

Not approved: _____ Approved: XX _____

Approved with modifications: _____

Scheduled Hearing Date: July 10, 2015

Exhibit #: RE-15-08-15

Chair's Signature: 

Date: July 10, 2015

Printed Name: Shawn Bergeron, Sr.