

NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM

Proposed amendment submitted by:

RE-15-10-15

Name: IRC Review Subcommittee

Date: 24 Nov 14

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: E-mail: 603-223-3888/ Bldgcodebrd@dos.nh.gov

Applicable code: 2015 IRC Applicable code section **Chapter 24**

Select only one code: IEBC-15 IBC-15 **IRC-15** IPC-15 IMC-15 IECC-15 IEBC-15 NEC-14 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

CHAPTER 24, FUEL GAS (entire chapter)

Check one: Delete without substitution: Add new section to read as follows:

Delete section and substitute the following: Revise section to read as follows:

Show Line through material to be deleted. Underline material to be added.

Proposed code language:

CHAPTER 24, FUEL GAS Fuel gas systems shall comply with the New Hampshire Fire Code, Saf-C 6000 (NFPA 54).

Reason / Justification: Fire Marshal has control of licensing Fuel gas fitters, and he prefers the NFPA code to the ICC code. (Carry over from amendments to 2009 IRC.)

Financial Analysis/Fiscal Impact of proposed amendment: None.


For Building Code Review Board Use:

Not approved: _____ Approved: XX _____

Approved with modifications: _____

Scheduled Hearing Date: July 10, 2015 _____

Exhibit #: RE-15-10-15 _____

Chair's Signature:  _____

Date: July 10, 2015 _____

Printed Name: Shawn Bergeron, Sr. _____