

NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM

Proposed amendment submitted by:

RE-15-11-15

Name: IRC Review Subcommittee

Date: 24 Nov 14

Company /Organization: State Building Code Review Board

Address: 33 Hazen Drive, Concord, NH 03305

Telephone: E-mail: 603-223-3888/ Bldgcodebrd@dos.nh.gov

Applicable code: 2015 IRC Applicable code **section P2603.5.1.**

Select only one code: IEBC-15 IBC-15 **IRC-15** IPC-15 IMC-15IECC-15 IEBC-15 NEC-14 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

P2603.5.1 Sewer Depth. Building Sewers that connect to private sewerage systems shall be not less than [NUMBER] inches (mm) below finished grade at the point of septic tank connection. Building sewers shall be not less than [NUMBER] inches (mm) below grade.

Check one: ___ Delete without substitution: ___ Add new section to read as follows:

Delete section and substitute the following: ___ Revise section to read as follows:

Show Line through material to be deleted. Underline material to be added.

Proposed code language:

P2603.5.1 Sewer depth. Building sewers that connect to private sewage disposal systems shall conform to RSA 485-A relative to minimum depth below finished grade. Building sewers that connect to public sewers shall be a minimum depth of 48 inches (1219 mm) below grade or adequately insulated to afford the same protection whenever a condition arises that the 48 inches (1219 mm) cannot be attained.

Reason / Justification: Bring code into line with existing NH laws. (Carry over from amendments to 2009 IRC.)

Financial Analysis/Fiscal Impact of proposed amendment: None.


For Building Code Review Board Use:

Not approved: _____ Approved: XX

Approved with modifications: _____

Scheduled Hearing Date: July 10, 2015

Exhibit #: RE-15-11-15

Chair's Signature: 

Date: July 10, 2015

Printed Name: Shawn Bergeron, Sr.