

**Questions and Answers**  
**NHDOT Design-Build Project Harts Location 16396A**  
**May 7, 2012**

**Question:**

- 1) RFP Section 3.1.1 #7 states that the structure over the Sawyer River shall accommodate the hydraulic opening as shown on the conceptual plans. Is the wingwall orientation shown on the conceptual plans (flared upstream wingwalls, u-back downstream wingwalls) considered part of the hydraulic opening?

**Response:**

Wingwall orientation shall be as follows:

- orientation of upstream wingwalls shall be flared
- orientation of downstream wingwalls shall be design-builder's choice

**Question:**

- 2) Has the public comment period for White Mountain National Forest approval begun yet, and if so, when does it end?

**Response:**

Public comment period has begun and will be completed prior to contract award.