

**STATE OF NEW HAMPSHIRE LIQUOR COMMISSION INVITATION TO SUBMIT
PROPOSAL FOR:**

**SECURITY ALARM AND FIRE PANEL
MONITORING, MAINTENANCE AND SERVICE**

RFP No. 2021-11-ALARM

COMMISSION'S RESPONSES TO PROPOSAL INQUIRIES

QUESTION 1:

Q: Is there a complete list of panels / device types / quantities per location for both fire alarm and security systems?

A: No. The NHLC does not have a complete list. Below is a list of certain devices and components that are currently in use:

- **Gemini P-3200 Security Panel (Standard Panel most stores)**
- **Gemini Gem-RP1CAe2 Keypad (Standard Keypad for most stores)**
- **Napco Gem-EZM8 (Standard Expansion Module for most store)**
- Hub-2A Latching Panic Button
- Visonic Duo-240 Motion Detector
- 4P4C Phone Jack (Surface Mount)
- RJ-31X Jack (Shorting bar between 1 and 4, 5 and 8)
- Resideo FG-1625 Glass Break (Flush or Surface Mount depending)
- GRI 4460A Surface mount Magnetic Door Contact
- Honeywell 7939-2 Surface Mount Magnetic Door Contact
- Securitron DPS-M-BK Magnetic Door Position Switch
- Seco-Larm SM-4201-LQ Track-mount Overhead Door Contact
- 18/2 Unshielded Wire (Plenum or Riser depending on the situation)
- 18/4 Unshielded Wire (Plenum or Riser depending on the situation)

QUESTION 2:

Q: On page 15, section 2 (pricing) you ask for preventative maintenance pricing for 3 years. Is this actually the annual inspection pricing?

A: The Preventative Maintenance pricing contained in Section 2 on page 15 of the RFP refers to the cost of performing all annual inspections and testing.

QUESTION 3:

Q: Can you clarify that all necessary panel and field device repairs are above and beyond the Preventative Maintenance/Inspection costs and that this contract does not request pricing for panel equipment repairs/batteries to be included in the contract pricing?

A: Yes. Panel and field device repairs are not included in the Preventative Maintenance pricing. Proposers shall provide their hourly rates for these services as required on RFP page 16, sections 2(C) and (D).