

RFB 2018-11 ALARM

Q1: Is there a detailed list of alarm equipment by store/location:

A1: The majority of our security alarm systems are NAPCO Gemini 3200 panels. We have a few variations and those are listed in the table below. Also, listed below are the make/models of each location that has a fire panel covered under this contract:

BURG/SECURITY EQUIPMENT LIST (other than NAPCO GEMINI)

Account Name	Address	City	State	Zip	Panel Type
15	6 ASH BROOK COURT	KEENE	NH	03431	Danco Silight Knight 4104B
66	ROUTE 3A, I-93 NORTH	HOOKSETT	NH	03106	DCS MAXSYS
67	25 SPRINGER ROAD, I-93 SOUTH	HOOKSETT	NH	03106	DCS MAXSYS

FIRE PANEL EQUIPMENT LIST

Account Name	City	Address	State	Zip	Panel Type
2 (FIRE)	W CHESTERFIELD	100 B ROUTE 9	NH	03443	Mircom UDACT-300A, DTC-300A and BB-1001/WPR
15 (FIRE)	KEENE	6 ASHBROOK COURT	NH	03431	EFB-200 w/CBC
18 (FIRE)	COLEBROOK	16 METALLACK DR	NH	03576	Honeywell Notfier NFW-50
19 (FIRE)	PLYMOUTH	22 RIDGE VIEW LANE	NH	03264	Honeywell Notifier NFW2-100
23 (FIRE)	CONWAY	234 WHITE MOUNTAIN HWY	NH	03818	Honeywell Fire Lite MS-5UD
38 (FIRE)	PORTSMOUTH	605 US INTERSTATE BY-PASS	NH	03801	UDACT-300A DTC-300A
44 (FIRE)	NEW HAMPTON	325 ROUTE 104	NH	03256	Honeywell Notifier NFW2-100
49 (FIRE)	PLAISTOW	32 PLAISTOW ROAD	NH	03865	Honeywell Fire-lite MS-5UD
55 (FIRE)	BEDFORD	9 LEAVY DRIVE	NH	03110	GE 10-500 GC
68 (FIRE)	NORTH HAMPTON	69 LAFAYETTE ROAD	NH	03862	GE Fireworx
73 (FIRE)	HAMPTON	INTERSTATE 95 S	NH	03843	Silent Knight 5104-B
76 (FIRE)	HAMPTON	INTERSTATE 95 N	NH	03843	Game Well x400 Silent knight Model 5104B
79 (FIRE)	EPPING	24 CALEF HIGHWAY, UNIT #4	NH	03042	Honeywell Notifier NFW2-100
81 (FIRE)	PEMBROKE	619 SAND ROAD	NH	03275	Honeywell Notifier NFW2-100- Annunciator by Honeywell
82 (FIRE)	WARNER	14 NICHOLS MILLS LANE	NH	03278	Honeywell Notifier Fire Warden 100-2

Q2: Is monitoring strictly via telco lines or are there cellular backups or internet monitoring at any sites:

A2: At this time all accounts are monitored via dial up POTS (telco) lines.

Q3: The RFP states "The Contractor shall repair or replace any defective components to maintain system integrity". Is the RFP asking for this component to be included in proposal pricing because just below in paragraph 4) the RFP also states "Any service required above and beyond normal manufacturer preventative maintenance will require an estimate..."?

A3: During preventative maintenance any defective or nonworking equipment is to be replaced to keep the system in working order and shall be included in the annual pricing. Any work that will exceed \$250.00 must be approved by the contract manager. And any equipment that is replaced outside of the preventative maintenance (via service call) is billed based on the hourly rate and % of material mark-up quoted in RFB submittal.

Q4: After award, will either the incumbent or state provide the passcodes/lock out codes to the system for programing and serving purposes?

A4: Contract manager will work with awarded vendor and previous vendor to facilitate a seamless transition.

Q5: Can you provide device counts for each location:

A5: The NH Liquor Commission does not compile data for which you seek.