

NEW HAMPSHIRE STATE BUILDING CODE PROPOSED AMENDMENT

Proposed amendment submitted by:

Name: Jerry Tepe, FAIA Date: January 30, 2018

Company/Jurisdiction: JRT-AIA Architect

Address: 741 Upper Straw Road, Hopkinton, NH 03229

Telephone: 603-223-9938 E-mail: jrtia@aol.com

Applicable code: IBC-09

Current code language (including section numbers):

Chapter 35 – Referenced Standards
ICC/ANSI A117.1—03 Accessible and Usable Buildings and Facilities

Proposed code language:

Chapter 35 – Referenced Standards
ICC A117.1—09 Accessible and Usable Buildings and Facilities

Reason/justification:

With the legislature reluctant to adopt the 2015 edition of the I-codes, I believe it is desirable and necessary to update this referenced standard. The 2010 ADA standards have been in effect since 2012 and the 2003 edition of this standard is not a good match while the 2009 standard is. While there is a more current A117.1 standard (2018) it is also not a good match for the 2010 ADA standard and will require numerous other substantial changes to the current accessibility design criteria; the 2009 standard does not have the same level of changes.



Code Board Action: _____ Date: 11 May 2018

Approved: Approved with modifications: _____ Not approved: _____

Modifications:
Shawn C. Bergeron Sr Chairman
