

**NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM**

Proposed amendment submitted by:

BD-15-07-15

Name: 2015 IBC Review Sub-committee
Date: April 10, 2015
Company /Organization: State Building Code Review Board
Address: 33 Hazen Drive, Concord, NH 03305
Telephone: 603-223-3889 E-mail: Bldgcodebrd@dos.nh.gov

Applicable code: **2015 IBC (adoption pending)** Applicable code section: 2902.2

Current 2015 IBC language (including section numbers): Exception three said 50 or less in 2009 and [P] 2902.2.1 is new in 2015 IBC (actually it appears to have been added in 2012)

[P] 2902.2 Separate facilities. Where plumbing fixtures are required, separate facilities shall be provided for each sex.

Exceptions:

1. Separate facilities shall not be required for *dwelling units* and *sleeping units*.
2. Separate facilities shall not be required in structures or tenant spaces with a total *occupant load*, including both the employees and customers, of 15 or fewer.
3. Separate facilities shall not be required in mercantile occupancies in which the maximum occupant load is 100 or less.

[P] 2902.2.1 Family or assisted-use toilet facilities serving as separate facilities. Where a building or tenant space requires a separate toilet facility for each sex and each toilet facility is required to have only one water closet, two family or assisted-use toilet facilities shall be permitted to serve as the required separate facilities. Family or assisted-use toilet facilities shall not be required to be identified for exclusive use by either sex as required by Section 2902.4.

Check one: Delete without substitution: Add new section to read as follows:
 Delete section and substitute the following: Revise section to read as follows:
 ~~Show Line through material to be deleted.~~ Underline material to be added.

Proposed code language:

[P] 2902.2 Separate facilities. Where plumbing fixtures are required, separate facilities shall be provided for each sex.

Exceptions:

1. Separate facilities shall not be required for *dwelling units* and *sleeping units*.
2. Separate facilities shall not be required in structures or tenant spaces with a total *occupant load*, including both the employees and customers, of 15 or fewer.
3. Separate facilities shall not be required in mercantile occupancies in which the maximum occupant load is 100 or less.
4. Separate facilities shall not be required in assembly occupancies that serve food with a total occupant load, including both employees and customers, of less than 25.

[P] 2902.2.1 Family or assisted-use toilet facilities serving as separate facilities. Where a building or tenant space requires a separate toilet facility for each sex and each toilet facility is required to have only one water closet, two family or assisted-use toilet facilities shall be permitted to serve as the required separate facilities. Family or assisted-use toilet facilities shall not be required to be identified for exclusive use by either sex as required by Section 2902.4.

Reason / Justification: This is a carry forward amendment. This should have corresponding language in the *IPC*, so the BCRB *IPC* sub-committee should weigh in.

Financial Analysis/Fiscal Impact of proposed amendment: This amendment has no fiscal impact when compared with the 2009 IBC along with NH amendments.


For Building Code Review Board Use:

Not approved: _____ Approved: XX _____

Approved with modifications: _____

Scheduled Hearing Date: July 10, 2015

Exhibit #: BD-15-07-15

Chair's Signature: 

Date: July 10, 2015

Printed Name: Shawn Bergeron, Sr.