

NEW HAMPSHIRE STATE BUILDING CODE  
PROPOSED AMENDMENT FORM

BD-15-12-18 ✓

Proposed amendment submitted by:

Name: Jerry R. Tepe, FAIA Date: December 18, 2018

Company /Organization: JRT-AIA Architect

Address: 741 Upper Straw Road, Hopkinton, NH 03229

Telephone: 603-223-9938 E-mail: jrtia@aol.com

Applicable code: IBC Applicable code section: 1105.1

Select only one code: IEBC-15 **IBC-15** IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-17 (NFPA 70)

Current language (including section numbers and include prior adopted amendments) as amended by Exhibit BD-15-05-15 and approved July 10, 2015:

**1105.1 Public entrances.** In addition to *accessible* entrances required by Sections 1105.1.1 through 1105.1.9, at least 60 percent of all *public entrances* shall be *accessible*.

**Exceptions:**

1. An *accessible* entrance is not required to areas not required to be *accessible*.
2. Loading and *service entrances* that are not the only entrance to a tenant space.

**1105.1.1 Parking garage entrances.** Where provided, direct access for pedestrians from parking structures to buildings or facility entrances shall be *accessible*.

**1105.1.2 Entrances from tunnels or elevated walkways.** Where direct access is provided for pedestrians from a pedestrian tunnel or elevated walkway to a building or facility, at least one entrance to the building or facility from each tunnel or walkway shall be *accessible*.

**1105.1.3 Restricted entrances.** Where *restricted entrances* are provided to a building or facility, at least one *restricted entrance* to the building or facility shall be *accessible*.

**1105.1.4 Entrances for inmates or detainees.** Where entrances used only by inmates or detainees and security personnel are provided at judicial facilities, detention facilities or correctional facilities, at least one such entrance shall be *accessible*.

**1105.1.5 Service entrances.** If a *service entrance* is the only entrance to a building or a tenant space in a facility, that entrance shall be *accessible*.

**1105.1.6 Tenant spaces.** At least one *accessible* entrance shall be provided to each tenant in a facility.

**Exception:** An *accessible* entrance is not required to self-service storage facilities that are not required to be *accessible*.

**1105.1.7 Dwelling units and sleeping units.** At least one *accessible* entrance shall be provided to each *dwelling unit* and *sleeping unit* in a facility.

**Exception:** An *accessible* entrance is not required to *dwelling units* and *sleeping units* that are not required to be *Accessible units*, *Type A units* or *Type B units*.

**1105.1.8** At least one of the required *accessible public entrances* in Groups A, E, I-1, I-2, I-3, R-1 and R-2 shall be equipped with automatic doors in compliance with ICC A117.1.

**1105.1.9** At least one of the required *accessible public entrances* in Groups B and M greater than or equal to 1,000 net square feet (93 m<sup>2</sup>) in size and the non-residential portion of live/work units per Section 419 greater than 1,000 net square feet (93 m<sup>2</sup>) shall be equipped with automatic doors in compliance with ICC A 117.1.

**1105.1.9.1** Required *accessible public entrances* in Groups B and M less than 1,000 net square feet (93 m<sup>2</sup>) in size and the nonresidential portion of live/work units per Section 419 less than 1,000 square feet (93 m<sup>2</sup>) where automatic doors are not provided, an electric signaling device to alert the owner of a presence at the door shall be provided.

Check one:  Delete without substitution:  Add new section to read as follows:  
 Delete section and substitute the following:  Further revise section to read as follows:

Show ~~Line through material to be deleted.~~ Underline material to be added.

Proposed code language (balance remains unchanged):

**1105.1.8** At least one of the required *accessible public entrances* in Groups A, E, I-1, I-2, I-3, R-1 and R-2 shall be equipped with either full power-operated or low-energy power-operated automatic doors in compliance with ICC A117.1.

**1105.1.9** At least one of the required *accessible public entrances* in Groups B and M greater than or equal to 1,000 net square feet (93 m<sup>2</sup>) in size and the non-residential portion of *live/work units* per Section 419 greater than or equal to 1,000 net square feet (93 m<sup>2</sup>) shall be equipped with either full power-operated or low-energy power-operated automatic doors in compliance with ICC A117.1.

**1105.1.9.1** Required *accessible public entrances* in Groups B and M less than 1,000 net square feet (93 m<sup>2</sup>) in size and the nonresidential portion of *live/work units* per Section 419 less than 1,000 square feet (93 m<sup>2</sup>) where automatic doors are not provided, an electric signaling device to alert the owner of a presence at the door shall be provided.

Reason / Justification:

Correcting/clarifying language.

Financial Analysis/Fiscal Impact of proposed amendment:

No fiscal impact as the added language clarifies requirements but does not add additional requirements.

---

For Building Code Review Board Use:

Not approved: \_\_\_\_\_ Approved:  \_\_\_\_\_ Approved with modifications: \_\_\_\_\_

Scheduled Hearing Date: 1-11-2019 Exhibit #: \_\_\_\_\_

Chair's Signature:  Date: 1-11-2019

Printed Name: Shawn G. Beggs Sr.

NH BCRB Proposed Amendment Form

12/14/2012