

NEW HAMPSHIRE STATE BUILDING CODE
PROPOSED AMENDMENT FORM

EX-15-11-19

Proposed amendment submitted by:

Name: Jerry R. Tepe, FAIA

Date: July 1, 2019

Company /Organization: JRT-AIA Architect

Address: 149 East Side Drive #341, Concord, NH 03301

Telephone: 603-223-9938

E-mail: jartaia@aol.com

Applicable code: IEBC

Applicable code section: 906.3, 1012.8.1 & 1105.1

Select only one code: IEBC-15 IBC-15 IRC-15 IPC-15 IMC-15 IECC-15 **IEBC-15** NEC-17 (NFPA 70)

Current language (including section numbers and include prior adopted amendments):

906.1 General. A building, *facility* or element that is altered shall comply with this section and Sections 705 and 806.

906.2 Type B dwelling or sleeping units. [No change]

1012.8.1 Partial change in occupancy. Where a portion of the building is changed to a new occupancy classification, any *alteration* shall comply with Sections 705, 806 and 906, as applicable.

1012.8.2 Complete change of occupancy. Where an entire building undergoes a *change of occupancy*, it shall comply with Section 1012.8.1 and shall have all of the following accessible features: [No change to subsections]

1105.1 Minimum requirements. Accessibility provisions for new construction shall apply to additions. An addition that affects the accessibility to, or contains an area of, *primary function* shall comply with the requirements of Sections 705, 806 and 906, as applicable. [No change to subsections]

Check one: Delete without substitution: Add new section to read as follows:

Delete section and substitute the following: Revise section to read as follows:

Show line through material to be deleted.

Underline material to be added.

Proposed code language:

906.3 Changing station. In assembly occupancies with an occupant load of 1,500 or greater and in mercantile occupancies of 40,000 square feet (3716 m²) or greater, a permanently mounted, powered, height adjustable adult changing station that complies with Section 603.5 of ICC A117.1 shall be provided in the altered toilet rooms, providing access to both male and female occupants, or family or assisted-use toilet room. Each room shall have signage meeting the requirements of ICC A117.1 indicating the presence of the changing station. Central directories, if provided, shall indicate the location(s) of the changing stations.

1012.8.1 Partial change in occupancy. Where a portion of the building is changed to a new occupancy classification, any *alteration* shall comply with Sections 705, 806 and 906, as amended and as applicable.

1105.1 Minimum requirements. Accessibility provisions for new construction shall apply to additions. An addition that affects the accessibility to, or contains an area of, *primary function* shall comply with the requirements of Sections 705, 806 and 906, as amended and as applicable.

Reason / Justification:

This is offered in response to recent legislation HB 628. Section 705.1.9 would require the toilet rooms to be accessible or, if technically infeasible, a family or assisted-use toilet room is required so the only added cost is the changing table itself. The change to Section 1012.8.1 and 1105.1 may not be necessary, but it points to the change in the section in NH.

Financial Analysis/Fiscal Impact of proposed amendment:

This will add to the cost of construction.

For Building Code Review Board Use:

Not approved: _____

Approved: _____

Approved with modifications:

Scheduled Hearing Date: _____

Exhibit #: EX-15-11-19

Chair's Signature: 

Date: Dec 13, 2019

Printed Name: Shawn G. Begeen br

the word "aggregate" after numeral 40,000 and before word square