

EXHIBIT 92

2009 INTERNATIONAL PLUMBING CODE

Proposed Amendment

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

605.22.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

PROPOSED LANGUAGE:

605.22.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

REASON: This amendment does not require the use of primer purple in color. Although it may be used, it is not required to be used. A primer is still required to be used. Purple primer, when spilled or dripped causes unsightly damage to the materials it comes in contact with.

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

705.8.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3, CSA CAN/CSA-B181.2 or CSA CAN/CSA-B182 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

PROPOSED LANGUAGE:

705.8.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A [purple] primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3, CSA CAN/CSA-B181.2 or CSA CAN/CSA-B182 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

REASON: See IPC Section 605.22.2

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

705.14.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3, CSA CAN/CSA-B181.2 or CSA CAN/CSA-B182 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

PROPOSED LANGUAGE:

705.14.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A [purple] primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA CAN/CSA-B137.3, CSA CAN/CSA-B181.2 or CSA CAN/CSA-B182 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

REASON: See IPC Section 605.22.2

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

Section P2905.9.1.3 PVC Plastic pipe. A purple primer that conforms to ASTM F 656 shall be applied to PVC solvent cemented joints. Solvent cement for PVC plastic pipe conforming to ASTM D 2564 shall be applied to all joint surfaces.

PROPOSED LANGUAGE:

Section P2905.9.1.3 PVC Plastic pipe. A purple primer that conforms to ASTM F 656 shall be applied to PVC solvent cemented joints. Solvent cement for PVC plastic pipe conforming to ASTM D 2564 shall be applied to all joint surfaces.

REASON: This is a consistency issue. The use of PVC primer purple in color, if approved in the 2009 IPC, should have the same limitation in the 2009 IRC.

In New Hampshire, purple-colored primer historically has not been required to be used when joining PVC pipe and fittings. When purple primer is dripped or spilled it stains the objects it comes in contact with causing an unsightly mess and costing the plumber and customer unexpected dollars. This proposed amendment does not specifically ban the use of purple primer, but it does not require the use of purple primer. Primer with no colorant will continue to be required.

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

P3003.9.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3, CSA B181.2 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

PROPOSED LANGUAGE:

P3003.9.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A ~~purple~~ primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3, CSA B181.2 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

REASON: This is a consistency issue. The use of PVC primer purple in color, if approved in the 2009 IPC, should have the same limitation in the 2009 IRC.

In New Hampshire, purple-colored primer historically has not been required to be used when joining PVC pipe and fittings. When purple primer is dripped or spilled it stains the objects it comes in contact with causing an unsightly mess and costing the plumber and customer unexpected dollars. This proposed amendment does not specifically ban the use of purple primer, but it does not require the use of purple primer. Primer with no colorant will continue to be required.

Submitted By: PFGFHVAC-NH
Phil Cocchiaro, President
76 Maple Street
Manchester, NH 03103
E-mail: info@pgfhvac.com

CURRENT LANGUAGE:

P3003.14.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3, CSA B181.2 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

PROPOSED LANGUAGE:

P3003.14.2 Solvent cementing. Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3, CSA B181.2 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM 2855. Solvent-cement joints shall be permitted above or below ground.

REASON: This is a consistency issue. The use of PVC primer purple in color, if approved in the 2009 IPC, should have the same limitation in the 2009 IRC.

In New Hampshire, purple-colored primer historically has not been required to be used when joining PVC pipe and fittings. When purple primer is dripped or spilled it stains the objects it comes in contact with causing an unsightly mess and costing the plumber and customer unexpected dollars. This proposed amendment does not specifically ban the use of purple primer, but it does not require the use of purple primer. Primer with no colorant will continue to be required.