

NEW HAMPSHIRE STATE BUILDING CODE  
PROPOSED AMENDMENT FORM

**PL-15-18-18**

Proposed amendment submitted by:

Name: Jerry R. Tepe, FAIA

Date: October 22, 2018

Company /Organization: JRT-AIA Architect

Address: 741 Upper Straw Road, Hopkinton, NH 03229

Telephone: 603-223-9938

E-mail: jrtia@aol.com

10:10

Applicable code: IPC

Applicable code section: 605.22.3

Select only one code: *IEBC-15 IBC-15 IRC-15 IPC-15 IMC-15 IECC-15 IEBC-15 NEC-17 (NFPA 70)*

Current language (including section numbers and include prior adopted amendments):

**605.22.3 Solvent cementing.** Joint surfaces shall be clean and free from moisture. A purple primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM D 2855. Solvent-cement joints shall be permitted above or below ground.

Check one:  Delete without substitution:

Add new section to read as follows:

Delete section and substitute the following:

XX Revise section to read as follows:

~~Show Line through material to be deleted.~~

Underline material to be added.

Proposed code language:

**605.22.3 Solvent cementing.** Joint surfaces shall be clean and free from moisture. A ~~purple~~ primer that conforms to ASTM F 656 shall be applied. Solvent cement not purple in color and conforming to ASTM D 2564 or CSA B137.3 shall be applied to all joint surfaces. The joint shall be made while the cement is wet and shall be in accordance with ASTM D 2855. Solvent-cement joints shall be permitted above or below ground.

Reason / Justification:

This is a carryover from the 2009 amendments that appears to have been overlooked. It matches a corresponding amendment to Section 705.11.2 in Exhibit PL-15-11-15.

Financial Analysis/Fiscal Impact of proposed amendment:

Clarification only – no fiscal impact.

For Building Code Review Board Use:

Not approved: \_\_\_\_\_

Approved:  \_\_\_\_\_

Approved with modifications: \_\_\_\_\_

Scheduled Hearing Date: \_\_\_\_\_

Exhibit #: \_\_\_\_\_

Chair's Signature: 

Date: 12-14-18

Printed Name: \_\_\_\_\_