



Robert L. Quinn
Commissioner

State of New Hampshire

DEPARTMENT OF SAFETY

Division of Fire Safety

Office of the State Fire Marshal

Office: 110 Smokey Bear Boulevard, Concord, NH 03301

Mailing Address: 33 Hazen Drive, Concord, NH 03305

Telephone: 603-223-4289 • **Fax:** 603-223-4294

www.nh.gov/firesafety



Paul J. Parisi
State Fire Marshal

BULLETIN #	TITLE			INITIAL RELEASE
2020-06	Emergency Declaration-Healthcare Occupancy Guidelines			March 17, 2020
REVISION #	RELEASED BY	APPROVED BY	SOURCE	REVISION DATE
	SPT	PJP	NFPA 101 & Governors Executive Order 2020-04	

Informational Bulletin 2020-06 Emergency Declaration – Healthcare Occupancy Guidelines

Purpose:

The purpose of this bulletin is to provide clarification and guidance for Healthcare Occupancies with regard to *Executive Order 2020-04 – An order declaring a state of emergency due to Novel Coronavirus (COVID-19)*.

This bulletin remains in effect for the duration of the state of emergency.

Background:

Specifically, under RSA 4:45, III(e), the Governor has the authority to "perform and exercise such other functions, powers, and duties as are necessary to promote and secure the safety and protection of the civilian population. The Governor has "power to make, amend, suspend and rescind necessary orders, rules and regulations" to carry out emergency management functions in the event of a disaster beyond local control.

The Commissioner of the Department of Health and Human Services may waive any of the licensing or credentialing requirements of RSA 151 and accompanying regulations with respect to any hospital or healthcare facility.

The State Fire Marshal has the authority to waive, on a case-by-case basis, the requirements of the provisions of the fire code. Variances can be obtained by contacting Deputy State Fire Marshal Sean Toomey (see below).

All persons or businesses wishing to waive or modify healthcare licensing requirements shall work with DHHS, the State Fire Marshal’s Office and their respective AHJ’s. Any changes shall be coordinated, and must provide adequate levels of fire safety as it relates to the New Hampshire State Fire Code. Any changes shall be reviewed and approved by the local fire chief.

This bulletin provides guidance on some of the frequently asked and anticipated conditions impacting fire and life safety in healthcare facilities during this state of emergency.

Guidance/Considerations:

Egress:

- At no time shall egress be compromised, blocked or locked
- Approved delayed egress is allowed as permitted in the Life Safety Code

Tents used for Temporary Screening Spaces:

- Any tents over 400 square feet shall meet the requirements of the Tent Inspection Checklist: <https://www.nh.gov/safety/divisions/firesafety/documents/TentInspectionChecklist.pdf>
- If temporary heating is installed, carbon monoxide alarms shall be provided
- Tents located adjacent to a building shall not obstruct egress or sprinkler systems under canopies

Conversion of non-patient areas to patient care areas need to consider the following:

(Examples: converting a conference room into a patient ward, converting medical office space/building into a patient room for overnight stay)

- Egress
- Ventilation
- Fire protection systems to include fire alarm and sprinkler systems
- Use of medical gas
- Defend in place strategy
- Staffing

Conversion of areas for daycare use by employee dependents:

- Space sized to accommodate 1 person/35 square feet
- Review space for sufficient egress
- Review fire protection systems in place

Sprinkler, Fire Alarm & Fire Protection System Inspections:

- Fire protection system inspections scheduled during this period may be rescheduled. Inspections must be completed within 30 days of the state of emergency being over.

This situation remains fluid and we are committed to working with all stakeholders to balance their needs while maintaining an adequate level of fire and life safety during this event. Any/all questions regarding modifications to the fire or life safety code should be directed to the following:

DHHS Life Safety

Wendy Smigelski: 271-9037

State Fire Marshal's Office

Deputy State Fire Marshal Sean Toomey: 223-4375